



SIP Industries
Quality Manufacturer Since 1960

Certificate of Compliance : Pipe to Pipe Bell Joint Restraint for DI Pipe - PTPVCDI

Date

SIP certifies that our 4" – 16" DI Pipe to Pipe Bell Joint Fitting Restraint for DI Pipe are designed, manufactured, and distributed as per the Waterworks industry standards. All castings are tested and traceable by casting markings to the below standards. Please refer to our website www.sipindustries.com for up to date product data and technical advisories.

Conformances

- ANSI/AWWA C110/A21.10 – Ductile-Iron and Gray-Iron Fittings for Water Service
- ANSI/AWWA C153/A21.53 – Ductile-Iron Compact Fittings for Water Service
- ANSI/AWWA C111/A21.11 – Rubber-Gasket Joints for Ductile-Iron Pressure Pipe Fittings
- 250 psi rating for 4" - 8" sizes, 200 psi rating for 10" & 12", 150 psi for 14", and 100 psi for 16"

- Harness Body** : Ductile Iron per ASTM A536, Grade 65-45-12
- Fasteners** : Rods & Nuts: High Strength-Low Alloy ASTM A242 Steel
Optional Type 304 or 316 Stainless Steel Bolts & Nuts available
- Coatings** : Alkyd, Direct to Metal (DTM) Enamel
Optional EZ-Shield® – Polyester Based Powder Coating

Listings and Approvals

- Foundry Certifications: ISO 9001

Markings and Traceability

All castings have markings for identifications and traceability. Heat and foundry codes are also cast on each casting for traceability. If material certifications are required, please identify on purchase documents prior to shipping from manufacturer.

Sincerely,

Roger Johnson
Director of Technical Services
rjohnson@sipindustries.com

Project Name	
Project Location	
Distributor	
Contractor	



SIP CORPORATE 8876 Gulf Freeway, Suite 500, Houston, TX 77017
SIP CENTRAL 2900 Patio Drive, Houston, TX 77017
SIP EAST 600 Rayloc Drive, Atlanta, GA 30336
SIP WEST 8333 Almeria Avenue, Fontana, CA 92335

Phone: 877-921-6111 or 713-923-6111 | Fax: 713-923-6114 | www.sipindustries.com | sales@sipindustries.com

V 0524-01